

New York City Administrative Code -

Title 28

New York City Construction Codes

3202.4.2 **Storm enclosures.** Storm enclosures projecting not more than 18 inches (457 mm) beyond the street line may be permitted during the period between November 15 and the following April 15. Such enclosures shall be removed at the end of this period. Construction of storm enclosures must comply with the requirements of this code including the fire resistance rating of the building to which it is appurtenant and Chapter 11 of this code.

[Previous Page](#) [Next Page](#)

Go To:

[Top of Page](#)

Last modified on 5/21/2010 11:18:00 AM

This site developed by New York Legal Publishing Corporation, www.nylp.com.